



## Fire And Emergency Services

Dr. Ambedkar Bhavan, Dhebar Road, Rajkot - 360 001. Phone No.0281 2227222.

RMC/RFES/Renew School Building/NOC/583/2021.

Date: 18.08.2021.

### -:: FIRE NO OBJECTION CERTIFICATE ::-

Ref. No.1.R.M.C.F.B.E.NO.NOC.464, DATE:-23.07.2021.

2.RMC/FB/Old Noc.No.272, Date :-24.07.2020.

This is to Renew School Fire No Objection Certificate That with Reference to Above Application of Building Plan for School Managing Trustee CMI Kelvani Mandal, "ST.XAVIER'S SCHOOL", Location:- Kalavad Road, Village:-Nanamava, Rajkot, Sr.No.76/P, O.P.No.3, F.P.No.28, T.P.S.No.2 (Nanamava), Building Floor :- G.F.+1<sup>st</sup> + 2<sup>nd</sup> Floor. Building Site Was Inspected by RMC Fire Brigade Fire Station Officers and The Documents Submitted Were Checked and Found Correct on Date:-04.08.2021.

• During inspection of the said premises following system were found adequate and in working condition.

- (1)Hose Reel in Working Condition each floor.
- (2)ABC Fire Extinguishers 6 kg Capacity each floor.
- (3)CO2 Fire Extinguishers 4.5 kg Capacity each floor.
- (4)Fire Pump ON/OFF Switch each floor.
- (5)Emergency Fire Alarm System each floor.

• You are hereby advised to maintain the above system in good working condition.

- (1)The Fire System to be Maintain perfect working condition all the time.
- (2)In Case of Emergency Fire Safety System must be operated by your trained person immediately.
- (3)The Fire Department of RMC will not be responsible for any loss of life & property Due to Fire/Emergency incident of your premises.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in Building Area.
- (5) Fire Water Tank for fire fighting in Above area.
- (6)Trained man power shall be available for Fire fighting premises round the clock.
- (7)Our fire Certificate is limited to Fire Fighting System available in your premises Only.
- (8)Any other instructions given by fire Department from time to time about fire Safety of the premises to be followed.
- (9)Any Accident Responsibility Owner/Management.
- (10)The duration of the Fire N.O.C. is valid up to One Year from the Date of Inspection.

  
Dy. Chief Fire Officer  
Fire & Emergency Services  
Rajkot Municipal Corporation



  
Chief Fire Officer  
Fire & Emergency Services  
Rajkot Municipal Corporation